

2. In compliance with ASTM Specification C 12-58-T for pipe laying and backfill, except no backfill shall be placed until the work has been inspected.
- (N) The connections of building sewers into the public sewer shall conform to the aforesaid requirements or to the standards of Water Pollution Control Federation Manual of Practice 29, whichever standard is more severe. Any deviation from the described procedures and materials must be approved by the Superintendent.

7-1-3: AUTHORITY OF ADMINISTRATIVE PERSONNEL:

ARTICLE 1: INSPECTION: The Superintendent with proper identification shall be permitted to enter onto all properties for the purposes of inspection, observation, measurement, sampling and testing pertinent to the discharge to the public system. The Superintendent may require additional samples or require a sampling control manhole in order to facilitate the sampling process.

ARTICLE 2: INDUSTRIAL PROCESSES: The Superintendent is authorized to obtain information concerning industrial processes which have a direct bearing on the kind and source of discharge. The Superintendent shall require plans and specifications for said private waste system prior to issuing a permit.

ARTICLE 3: EASEMENTS: The Superintendent, with proper identification, shall be permitted to enter all private properties through which the Village holds an easement. Under the terms of pre-existing conditions, should the Village discover sewer lines lying under private property without duly negotiated easements, the Village may authorize the Superintendent to enter upon and conduct such activities as necessary to maintain the collection system. The Village hereby assumes any contingent liability for damage to private property as may result from said actions as determined by the actual status of the physical condition of the surface land.

ARTICLE 4: PROTECTION OF SEWER SYSTEM: Pursuant to its authority to make, enact and enforce ordinances for improvement, care and protection of the Village and its waste treatment system, and of its public water supply outside the Village, and of standards for control of

subdivisions within one and one-half (1 ½) miles of the Village limits, the officers and employees of the Village are hereby authorized to enforce this ordinance and other amendable laws and ordinances or other agencies which are conducive to the preservation of public health, comfort and welfare and which may render the waste discharges harmless insofar as reasonably possible to do so.

7-1-4: PENALTY: Failure to comply with provisions of this ordinance shall constitute a violation of a general ordinance of the Village with such minimum penalty as may be the discontinuance of service and/or a fine determined by a Court of competent jurisdiction in an amount not to exceed five hundred dollars (\$500.00) per day plus Court costs incurred in securing compliance, which may include any expense, loss or damage occasioned by reason of such violation.

7-1-5: TESTING:

- (A) Testing shall be performed as determined by the Superintendent to adequately ascertain the waste discharge levels of flow, BOD, and SS in order to comply with applicable provisions of the act.
- (B) The Village shall revise the sewer charges periodically, in accordance with the flow and strength of waste determined in Section 7-1-5(A).

7-1-6: IMPLEMENTATION: The rates enacted in Sections 7-1-2 and 7-1-3 above shall become effective on and after the due passage of this ordinance; provided further that billing shall begin when notice of same rates implementation is given by resolution established by the Board of Trustees.